

APPLICATION FOR RETAIL FIREWORKS PERMIT
ANDERSON COUNTY KENTUCKY

Address or Description of Retail Sales Location: _____

Primary On Site Manager or Contact Person: _____

Phone Numbers: On Site ____ - ____ - ____ Other: ____ - ____ - ____

Applicant Name: _____ Phone Number: ____ - ____ - ____

 Address City State Zip Code

Consumer Fireworks Retail Sales ("CFRS") Facility
 Permanent CFRS Facility Temporary/Seasonal CFRS Facility

Facility

The information you are to provide in this box is about the facility itself(tent,hard stand,etc...) not the land or property as described in "Retail Sales Location". The detailed description shall include the building name and owner, and owner's contact information, if applicable.

By signing below I certify and attest to the following:

- * I understand, and will comply with, all governances associated with this activity including the Kentucky Revised Statues, Anderson County Ordinances, local zoning requirements, and the National Fire Protection Association Standard 1 - Fire Code Chapter 65: and
- * Attached here to is a valid Kentucky Retail Fireworks permit, proof that I have been issued an occupational business license from Anderson County KY, and proof of liability insurance as required: and
- * Attached hereto is a facility drawing and site plan for the Retail Sales Location listed above: and
- * I, on behalf of myself and any entity I represent as the applicant, do hereby consent to periodic inspections of the Retail Sales Location by County Officials, Fire Chief or his designee, and law enforcement at any time and, Fireworks being sold at this location were supplied by/from: _____
- * A seasonal permit, once issued, is valid for a period of 60 days from the effective date. I request the effective date of the permit to be ____ / ____ / ____ with sale dates limited to 6/10/11-7/07/11 & 12/26/11-1/04/12

 Applicant Signature Date

Planning/Zoning Authorized Official: _____ Date ____ / ____ / ____

Approve Disapprove

Fire Department Authorized Official: _____ Date ____ / ____ / ____

Approve Disapprove

Fireworks Code Regulations for Tents & Temporary Stands

- **NO Smoking Signs**

1. NO Smoking in or within 50 feet of **Consumer Fireworks Retail Sales (CFRS)** NFPA 1 – 65.10.3.11.1
2. NO smoking signs posted at each entrance or within 10 feet of every aisle. “FIREWORKS – NO SMOKING” signs posted in 2 inch lettering with contrast background NFPA 1 – 65.10.3.11.2

****NOTE:** In accordance with NFPA 1 Section 65.10.4.8.3 and 65.10.4.8.4, exit signs and emergency lights are not required for tents to be illuminated that are not open for business after dusk in accordance with NFPA 1124 section 7.4.8.3 and 7.4.8.4.

- **Separation Distances for Temporary Consumer Fireworks Retail Sales (CFRS)**

1. 50 feet from motor fuel dispensing station NFPA 1 – 65.10.3.12.2
2. 50 feet from retail propane dispensing station NFPA1 - 65.10.3.12.1
3. 50 feet from aboveground storage tank (AGST) NFPA1 - 65.10.3.12.1
4. 300 feet from bulk fuel dispensing or bulk storage NFPA 1 – 65.10.3.12.6
5. 20 feet from buildings NFPA 1 – 65.10.4.7.2
6. 20 feet from combustibles NFPA 1 – 65.10.4.7.2
7. 10 feet from parked vehicles NFPA 1 – 65.10.4.7.2
8. 20 feet from storage of consumer fireworks NFPA 1 – 65.10.4.7.2
9. 20 feet from generator fuel storage NFPA 1 – 65.10.4.9.2.3
10. 20 feet from generator placement NFPA 1 – 65.10.4.9.2.2
11. 20 feet from cooking equipment NFPA 1 – 65.10.4.9.3.1
12. 50 feet from any open flame cooking equipment NFPA 1 – 65.10.4.9.3.2

- **Proper Use of Extension Cords**

1. Extension cords maintained in good working condition.
2. Extension cords shall be grounded when serving ground appliances.
3. Extension cords cannot be used as permanent wiring.
4. Extension cords shall be rated for its use.
5. Extension cords shall be plugged directly into an approved receptacle, powertap or multi-plug adapter.

NFPA 1 – 11.1.7

- **Fire Extinguishers**

1. Travel distance to extinguisher shall be 35 feet or less NFPA 1 – 65.10.4.5.2
2. Every CFRS facility and store shall have a minimum of 2 portable Fire extinguishers (one 2A rating and one 2 ½ gallon pressurized water type extinguisher) NFPA 1 -65.10.3.6.3

- **Notification to Local Fire Department of storage.**

1. (Shall include address of sales, address, where fireworks are stored, and how they are stored, copy of shipping bill or manifest and whether fireworks are consumer, theatrical pyro or display.) KRS 227.752(3)
2. 24 hours to comply with any non-imminent danger violations. KRS 227.752(4)

Fireworks Code Regulations for Tents & Temporary Stands

- **Discharging Fireworks Signage** - One sign shall be posted on exterior of each side of the CFRS stating “No fireworks discharge within 200 feet.”
4 Inch lettering on contrast Background. NFPA 1 – 65.10.4.6.3
KRS 227.715(11)
- **Ignition of fireworks** - person lawfully possessing consumer fireworks may use them if: 18 years old, fireworks not ignited within 200 feet of any structure, vehicle or other person. KRS 227.715(11)
- **Temporary Stands (Not accessible to the public)**
 1. Maximum height of displays – 8 feet. NFPA 1 – 65.10.6.4.3
 2. Items shall not be required to have covered fuses NFPA 1 – 65.10.6.4.5
 3. Fireworks shall be displayed in a manner that prevents handling by persons other than staff NFPA 1 – 65.10.6.4.6
- **Temporary Stands (accessible to the public)**
 1. Stands less than 200 square feet only 1 fire extinguisher required NFPA 1 – 65.10.6.2.1
 2. Approved safety and evacuation plan not required NFPA 1 – 65.10.6.2.2
 3. Travel distance to exits shall not exceed 35 feet NFPA 1 - 65.10.6.2.3.2
- **Under The Influence** - NO sale of fireworks to anyone obviously under the influence of alcohol or drugs NFPA 1 – 65.10.3.23
- **Training** - All personnel handling consumer fireworks shall receive training to the performance of their duties. NFPA 1 – 65.10.3.22
- **Building Permit for Tent** - Building permit must be obtained to the installation or erection of a tent over 399 square feet 2013 KBC – 105.1
- **Fireworks registration displayed conspicuously for each location selling fireworks** KRS 227.715(6)
- **No person under 18 years old shall sell consumer fireworks at CFRS facility without supervision of parent or guardian** KRS 227.715(9)
- **No person shall give, offer for sell any consumer fireworks to anyone under 18 years old** KRS 227.715(8)